

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 12:00 pm

**PWS ID:** UTAH10021      **Name:** ARCHES NATIONAL PARK HQ

**Legal Contact:** NPS - ARCHES NATIONAL PARK      **Rating:** Approved  
KATE CANNON      **Rating Date:** 04/09/1996

**Address:** 2282 SW RESOURCE BLVD      **Activity Status:** Active  
MOAB, UT 84532

**Phone Number:** 435-719-2251

**City Served (Area):**

**County:** GRAND COUNTY

**System Type:** Non-community      **Last Inv Update:** 03/01/2011      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 02/25/2009      **Total Dsgn Cap:**  
**Population:** 25      **Surveyor:** JIM ADAMSON      **Total Emerg Cap:**  
**Oper Period:** 1/1 to 12/31

**Gal/Day   Gal/Min**

### Contacts

Contact Type	Name	Title	Phone Numbers Office      Emergency	Email Address
AC	CANNON, KATE	SUPERINTEND	435-719-2101	

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Metered	0	15
Residential	Unknown	0	5
Commercial	Unknown	0	6
			26      Total Svc Connections

### Storage

**Total Storage:** 50,000 GAL      **Number of Units:** 1      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	HEADQUARTERS TANK #1	Ground	50,000 GAL	Steel		A	NO

### Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	HEADQUARTERS CHLORINATOR		A	

### Distribution System

Pump Type	Total Dyn Head ft H2O      P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL #1	Active	WL	8	35 GPM	38 GPM	Yes	GW	Permanent	1/1 to 12/31	

\*Reports measured flow for wells, approved design capacity for all other sources.